



M & W INCOM SUPPLY

Drip Irrigation System

Two Year Maintenance Agreement

Your two year maintenance agreement covers checking your system twice per year for the following operations based on your system's designed/as built conditions:

1. **Field Conditions** - walk the drip field and record any visible wet spots
2. **Controller** - confirm input and output on microprocessor
3. **Septic and Pump Tank** - check both tanks for structural integrity, examine floats and electrical connections.
4. **Pump and Valve Operation** - check pump for hand and automatic operation. Check each zone valve for flow and proper operation. Check zone master if applicable. Backwash all filters.
5. **Hydraulic Unit** - examine filters and clean as needed. Examine all hydraulic components for leaks, tubing crimps, and other problems.
6. **Extended Check** - check zone dose rates and air release valves. Check flushing rates and run times for all zones. Make minor adjustments if necessary.
7. **Solid Levels** - Check solid levels in septic tank ONCE PER YEAR (if applicable), and advise if tank needs pumping. If pumping is advised, homeowner will schedule service by others at their own expense.
8. **Provide Report to Customer** - if anything is out of compliance, form action plan to resolve issue.

Any parts required and/or labor required to install said parts in order to maintain proper operation of your system are not included as part of this maintenance agreement.

Any other service required for your system, such as alarm calls, other repairs, etc., are not covered under this maintenance agreement and will be charged at current labor rates, portal to portal.

PRINT NAME: _____

SIGNATURE: _____

ADDRESS: _____

DATE: ____ / ____ / ____

PHONE #: _____